

Ведомость потребления электрической мощности (Р) за замерный день 20.12.2019г.

Потребитель АО "Анапоро-ананьевский завод"

наименование присоединения	точка замера/тепловая функция присоединения	коэффициент спроса	количество часов																									
			время суток																									
ТП-110/10 "Анапс" №17	III-сд-10кВ	U	0.00	1.00	2.00	3.00	4.00	5.00	6.00	7.00	8.00	9.00	10.00	11.00	12.00	13.00	14.00	15.00	16.00	17.00	18.00	19.00	20.00	21.00	22.00	23.00	24.00	
			10.8	10.8	10.8	10.8	10.8	10.8	10.7	10.6	10.5	10.4	10.3	10.3	10.4	10.4	10.4	10.5	10.5	10.5	10.5	10.6	10.7	10.7	10.8	10.8	10.8	
			Р	0.21	0.69	0.72	0.73	1.01	1.08	1.21	1.41	1.38	1.54	1.38	1.30	1.17	1.23	1.11	0.83	0.77	0.73	0.70	0.68	0.68	0.66	0.65	0.65	
			Q	0.59	0.59	0.61	0.60	0.60	0.62	0.66	0.60	0.55	0.86	0.80	0.76	0.64	0.61	0.75	0.67	0.64	0.62	0.60	0.59	0.59	0.60	0.61	0.62	
		I	65.3	63.7	66.4	67.1	93.1	100.0	113.2	113.4	116.1	148.3	134.2	135.9	131.5	118.1	108.6	79.0	73.7	69.8	66.2	64.1	63.2	63.3	61.4	59.9	60.0	
			теп	0.83	0.86	0.84	0.83	0.80	0.57	0.54	0.57	0.62	0.56	0.56	0.59	0.62	0.66	0.68	0.80	0.82	0.85	0.86	0.88	0.89	0.91	0.94	0.95	
			сгор	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	
			сгор																									
ТП-110/10 "Анапс" №19	I-сд-10кВ	U	10.8	10.8	10.8	10.8	10.8	10.8	10.7	10.6	10.5	10.4	10.3	10.3	10.4	10.4	10.4	10.4	10.5	10.5	10.5	10.6	10.7	10.7	10.8	10.8	10.8	
			Р	0.24	0.23	0.89	0.88	0.90	1.12	1.51	1.88	2.01	1.91	1.90	1.86	1.95	1.91	1.66	1.42	1.28	1.20	1.19	1.16	1.17	1.05	1.04	1.00	0.97
			Q	0.95	0.94	0.93	0.91	0.92	0.94	1.09	1.26	1.26	1.28	1.10	1.18	1.23	1.20	1.13	1.05	0.95	0.95	0.97	0.96	0.96	0.96	0.95	0.95	
			теп	87.4	85.9	82.0	83.6	103.2	140.8	177.6	191.0	183.4	146.5	180.7	177.9	172.7	159.5	135.6	121.5	114.3	111.9	109.1	109.2	97.8	96.7	92.4	89.7	
		I	1.00	0.99	0.95	0.96	0.98	0.96	0.84	0.72	0.67	0.61	0.67	0.63	0.63	0.66	0.67	0.68	0.74	0.82	0.82	0.83	0.83	0.92	0.91	0.95	0.99	
			сгор	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	
			сгор																									
			сгор																									
ТП-110/10 "Анапс" №36	IV-сд-10кВ	U	10.8	10.8	10.8	10.8	10.8	10.8	10.7	10.6	10.5	10.4	10.3	10.3	10.4	10.4	10.4	10.4	10.5	10.5	10.5	10.6	10.7	10.7	10.8	10.8	10.8	
			Р	0.27	0.26	0.27	0.27	0.27	0.26	0.25	0.23	0.29	0.33	0.37	0.36	0.34	0.31	0.35	0.33	0.34	0.37	0.35	0.32	0.32	0.33	0.30	0.31	
			Q	0.12	0.12	0.12	0.13	0.13	0.13	0.14	0.14	0.21	0.29	0.33	0.27	0.26	0.35	0.29	0.23	0.25	0.24	0.22	0.21	0.20	0.21	0.16	0.16	
			теп	24.6	24.4	24.9	25.0	25.3	24.4	23.3	22.1	27.1	31.9	36.0	34.5	32.8	33.9	31.0	30.6	34.9	32.8	30.2	29.7	30.7	27.8	27.7	26.4	
		I	0.46	0.45	0.45	0.49	0.48	0.49	0.54	0.58	0.73	0.66	0.88	0.77	0.75	0.85	0.81	0.72	0.73	0.65	0.64	0.66	0.64	0.65	0.54	0.55	0.51	
			сгор	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	
			сгор																									
			сгор																									
ТП-110/10 "Анапс" №37	III-сд-10кВ	U	10.8	10.8	10.8	10.8	10.8	10.8	10.7	10.6	10.5	10.4	10.3	10.3	10.4	10.4	10.4	10.4	10.5	10.5	10.5	10.6	10.7	10.7	10.8	10.8	10.8	
			Р	1.88	1.04	0.15	0.15	0.16	0.32	1.92	2.34	2.33	2.32	2.27	2.16	2.25	2.24	2.17	1.18	0.18	0.15	0.14	0.14	0.14	0.14	0.13	0.13	
			Q	0.70	0.45	0.09	0.09	0.09	0.17	0.75	0.88	0.89	0.90	0.89	0.90	0.89	0.87	0.95	0.43	0.08	0.08	0.09	0.09	0.09	0.09	0.09	0.09	
			теп	174.0	95.9	13.9	13.8	14.6	79.8	179.8	220.8	223.3	223.6	220.6	219.0	216.6	215.3	208.2	112.7	17.1	13.9	13.3	12.8	12.7	12.7	12.4	12.3	
		I	0.37	0.43	0.61	0.60	0.56	0.59	0.39	0.38	0.38	0.39	0.39	0.40	0.39	0.39	0.39	0.36	0.44	0.57	0.60	0.62	0.64	0.65	0.67	0.69	0.70	
			сгор	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	
			сгор																									
			сгор																									
ТП-110/10 "Анапс" №39	III-сд-10кВ	U	10.8	10.8	10.8	10.8	10.8	10.8	10.7	10.6	10.5	10.4	10.3	10.3	10.4	10.4	10.4	10.4	10.5	10.5	10.5	10.6	10.6	10.7	10.7	10.8	10.8	
			Р	0.13	0.13	0.13	0.14	0.16	0.25	0.31	0.27	0.31	0.47	0.46	0.44	0.44	0.45	0.25	0.16	0.16	0.16	0.16	0.15	0.14	0.13	0.12	0.13	
			Q	0.05	0.04	0.05	0.05	0.06	0.14	0.21	0.28	0.22	0.25	0.22	0.23	0.24	0.24	0.13	0.11	0.08	0.08	0.07	0.07	0.05	0.05	0.05	0.05	
			теп	12.0	11.9	12.2	12.1	13.2	14.4	22.9	28.8	35.1	29.8	45.9	43.2	42.6	41.9	43.1	24.0	14.7	15.1	15.2	15.1	14.0	12.9	11.8	11.5	
		I	0.35	0.34	0.36	0.34	0.38	0.39	0.57	0.70	0.75	0.70	0.53	0.50	0.53	0.55	0.53	0.53	0.55	0.53	0.53	0.47	0.45	0.43	0.35	0.36	0.38	
			сгор	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	
			сгор																									
			сгор																									
ТП-110/10 "Анапс" №42	IV-сд-10кВ	U	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.7	10.6	10.5	10.4	10.3	10.3	10.4	10.4	10.4	10.4	10.5	10.5	10.5	10.6	10.6	10.7	10.8	10.8	
			Р	1.86	1.04	0.15	0.15	0.16	0.32	1.92	2.34	2.33	2.32	2.27	2.16	2.25	2.24	2.17	1.18	0.18	0.15	0.14	0.14	0.14	0.14	0.13	0.13	
			Q	0.70	0.45	0.09	0.09	0.09	0.17	0.75	0.88	0.89	0.90	0.89	0.90	0.89	0.87	0.95	0.43	0.08	0.08	0.09	0.09	0.09	0.09	0.09	0.09	
			теп	174.0	95.9	13.9	13.8	14.6	79.8	179.8	220.8	223.3	223.6	220.6	219.0	216.6	215.3	208.2	112.7	17.1	13.9	13.3	12.8	12.7	12.7	12.4	12.3	
		I	0.37	0.43	0.61	0.60	0.56	0.59	0.39	0.38	0.38	0.39	0.39	0.40	0.39	0.39	0.39	0.36	0.44	0.57	0.60	0.62	0.64	0.65	0.67	0.69	0.70	
			сгор	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	
			сгор																									
			сгор																									
ТП-110/10 "Анапс" №43	IV-сд-10кВ	U	10.8	10.8	10.8	10.8	10.8	10.8	10.7	10.6	10.5	10.4	10.3	10.3	10.4	10.4	10.4	10.4	10.5	10.5	10.5	10.6	10.6	10.7	10.7	10.8	10.8	
			Р	1.86	1.04	0.15	0.15	0.16	0.32	1.92	2.34	2.33	2.32	2.27	2.16	2.25	2.24	2.17	1.18	0.18								

Главный энергетик - начальник РЭЦ

Е.А. Курносов

На 2-х листах. Лист 2.

